




Components of solar systems

- storage
- heat exchangers
- safety and protection devices
- air vents, check valve
- control & measurement






Thermosiphon circulation system



Thermosiphon circulation system





- **circulation induced by buoyancy effect**
 - difference in densities (temperatures) of fluid

water density: 20 °C is 998 kg/m³
 80 °C only 972 kg/m³.... Dif ..26kg

- **self-controlled system**
 - higher temperature in collector – higher circulation (flowrate)




Thermosiphon circulation system



at least 1 m vertical elevation of storage above solar collector



Components of solar system






Forced circulation system



Forced circulation system




© www.solarpraxis.com

- **circulation induced by pump**
 - collector above storage
 - no limits
- **electronic controller**
 - measurement of temperature difference between collector and storage – signal for switching the pump on/off




Components of solar system





Storage tanks – hot water


- no heat exchanger (storage vessel)
- one heat exchanger (monovalent storage tank)
- two heat exchangers (bivalent storage tank)






Storage tanks – combined with SH

- tank in tank (DHW tank in SH tank)
- with tube heat exchanger (DHW heat exchanger in SH tank)



small heat
transfer area
small loads
1 – 2 persons



double small heat
transfer surface
higher loads
3 – 4 persons



What size ?

- **domestic hot water**
 - 50 l/m² collector aperture area


- **combined with heating**
 - 50 to 70 l/m² collector aperture area
 - larger if backup heater supply heat into store
 - biomass boiler (logs) 50 l/kW
 - automatic biomass boiler (pellets) 25 l/kW
 - heat pump 15 to 30 l/kW
 - gas boilers 25 l/kW





What size ?

- **solar combitank**
 - one for solar system and back-up
 - one for DHW and SH
- **example**
 - solar system 10 m²
 - biomass boiler 10 kW
 - **2/3 volume = cca 500 l**
 - **storage size 750 l**






Exergy


usability of stored heat ~ usable temperature

stratified storage



300 l

mixed storage



300 l

thermal stratification = higher efficiency, higher solar fraction




Factors influencing stratification

- aspect ratio of tank: Height / Diameter
- heat input (stratified, fixed)
- cold water input (bottom, prevented mixing)
- return flow from heating system input (stratified)
- heat loss of storage, thermal bridges
- stratification devices (for development of stratified volume)



Controlled stratification




$$\rho_7 < \rho$$

$$\rho_6 > \rho$$

$$\rho_5 > \rho$$

input of hot water into layer with similar temperature thanks to similar density
(passive device)



$$\rho_7 < \rho$$


$$\rho_6 > \rho$$

$$\rho_5 > \rho$$

$$T_7 > T$$

$$T_6 < T$$


$$T_5 < T$$



complex control
(active device)



Stratification devices in combined tank





Heat exchangers (internal)



- **tube heat exchanger** immersed in the tank
 $U\text{-values} = 120 \text{ to } 300 \text{ W/m}^2\text{K}$ Thermal Transmittance

for small
systems $< 20 \text{ m}^2$

- (laminar flow, natural convection)

- , 0.4 m² ribbed tubes / m² col.area,

- 0.2 m² bare exchange tubes / m² col.area





Heat exchangers (external)

- **plate heat exchanger** out of the tank

$U\text{-values} = 1500 \text{ to } 3500 \text{ W/m}^2\text{K}$

(turbulent flow, forced convection)



for larger
systems $> 20 \text{ m}^2$

- **tube and shell heat exchangers** (swimming pools)

$U = 500 \text{ až } 1000 \text{ W/m}^2\text{K}$

(laminar / turbulent flow)

0.05 to 0.08 m^2 exchange area / m^2 col.area





Heat exchangers - Heat power

- compared to nominal conditions: lower temperatures in SOLAR, lower flowrates, higher viscosity (antifreeze mixtures), laminar flow

→ **lower heat transfer rate (*U*-value)**

$$\dot{Q} = U \cdot A \cdot \Delta t_m$$

change of heat power for given heat exchanger

nominal conditions (80/60 °C – 20°C, 1,5 m³/h) = **150 kW**

solar system conditions (55/45 °C – 20°C, 0,4 m³/h) = **5 kW**

selection of heat exchangers with high heat transfer surface *A*




Plate heat exchangers

$$Q = 26 \text{ kW}$$

$$\Delta t_m = 3.3 \text{ K}$$

$$\Delta t_m \text{ Arithmetic Mean Temperature Difference} \\ = (t_{pi} + t_{po}) / 2 - (t_{si} + t_{so}) / 2$$




$$U = 2000 \text{ W/m}^2\text{K}$$

$$A = 4 \text{ m}^2$$

$$Q = 17 \text{ kW}$$

$$\Delta t_m = 13 \text{ K}$$




$$U = 1000 \text{ W/m}^2\text{K}$$

$$A = 1.3 \text{ m}^2$$




Stagnation





Stagnation



- **state without a heat removal from collectors at incident solar radiation**
- **causation:**
 - storage temperature achieves the limit value, controller stops the circulation pump
 - blackout
 - incompetent intervention (closure of collector loop)
- **consequence**
 - increase of temperature in solar collector
 - balance state: energy input = heat loss
 - collector achieves maximum temperature at given conditions
 - boiling of fluid, steam production




Stagnation temperature

- depends on conditions
 - extreme (nominal) conditions: $G = 1000 \text{ W/m}^2$, $t_e = 30 \text{ }^\circ\text{C}$
 - calculation from intersection of efficiency characteristic with horizontal axis

$$t_{stg} = 30 + 1000 \cdot \left(\frac{t_m - t_e}{G} \right)_{\eta=0}$$

- positive root of parabola

$$\left(\frac{t_m - t_e}{G} \right)_{\eta=0} = \frac{a_1 - \sqrt{a_1^2 + 4 \cdot \eta_0 \cdot a_2 \cdot G}}{-2 \cdot a_2 \cdot G}$$





Stagnation temperature


collector type	t_{stg} [°C]
unglazed collector	50 - 65
glazed non-selective collector	90 – 110
glazed selective collector	150 – 180
vacuum tube collector	250 - 300

solar collector has to withstand it

temperatures could be lower dependent on real climate conditions




Stagnation behaviour



1. liquid is expanding
2. achieves boiling point (at given pressure), boiling starts
 - first bubbles appear, saturated steam, liquid is expelled from collector



Stagnation behaviour




3. rest of liquid is transformed in steam

- volume of collector is filled by steam, high heat removal



Stagnation behaviour




4. superheating of steam in collector

- emptying of collector, stable state, collector full of steam phase



Stagnation behaviour




5. decrease of radiation, decrease of temperature

- condensation, liquid phase fills up the collector back




Stagnation behaviour






Emptying of solar collectors

good



bad





Types of solar liquids

- **water**

- nontoxic, nonflammable, cheap, high thermal capacity, low viscosity
- limited usable temperature range (seasonal systems),

- **ethylenglycol**





- antifreeze mixture with water, toxic, low viscosity

- **propylenglycol**

- antifreeze mixture with water, high viscosity dependent on temperature, low thermal capacity (lower by 20 % than water), corrosion inhibitors, stabilisers and other additives




Properties of propylenglycol-water



<http://www.mrc-eng.com/Downloads/Brine%20Properties.pdf>



Kinematic viscosity





Piping and thermal insulation

- **durability**
 - resistant to pressures and temperatures
 - ageing, atmospheric conditions
- **energy performance**
 - piping – low pressure loss, consumption of electricity for pumps
 - thermal insulation – low heat loss, efficiency and gains of solar system, use of back-up heating




Materials for pipes

- **plastic pipes**
 - EPDM, UV protection, only swimming pools
- **copper pipes**
 - easy connections, soldering, pressing, same material as collectors, zero electro/chemical potential (corrosion)
- **steel pipes**
 - welding, complicated assembly, low price!
- **stainless steel (corrugated)**
 - easy assembly, formable, also for heat exchangers




Copper pipes

Standardized Tube



Certified Tube





Copper pipes



soldering



pressing



Steel pipes





Pipe dimension

- required flowrate in collector loop
 - **low-flow** systems: 10 to 20 l/h.m²
high ΔT at collector 25 to 40 K
 - **high-flow** systems: 50 to 100 l/h.m²
low ΔT at collectors 5 to 10 K
- recommended velocity in pipes $w = 0,5$ m/s

$$d = \sqrt{\frac{4 \cdot \dot{M}}{\pi \cdot w \cdot \rho}}$$



Thermal insulation - requirements

- **resistance to high temperatures**
 - at collector: stagnation temperatures min. 170 °C
 - distant places: min. 120 °C

- **resistance to ambient environment**
 - humidity – increase of loss, degradation **closed cells**
 - UV radiation – carbon additives
 - birds – „tasty“ material





Materials for thermal insulation


- **EPDM foams, syntetic rubber**
 - (+) low thermal conductivity
 - (+) closed structure
 - (0) UV protection
 - (–) birds
 - resistance:
 - 170 °C short-term
 - 130 °C long-term





Materials for thermal insulation

- mineral wool (glass, stone)
 - (+) UV radiation
 - (–) open structure
need for sheeting (aluminium)
 - (+) long-term resistance to
280 °C






Pipe heat loss

$$U = \frac{\pi}{\frac{1}{2\lambda_{iz}} \ln\left(\frac{d_e + 2 \cdot s_{iz}}{d_e}\right) + \frac{1}{\alpha_e} \cdot \frac{1}{(d_e + 2 \cdot s_{iz})}} \quad [\text{W/m.K}]$$

$$\dot{Q} = U \cdot L \cdot (t_w - t_e)$$

■ typical values

- insulation thickness s_{iz} = dimension d_e





Insulated piping






Safety and protection devices

- **safety valve**
 - protects the collector loop against non-permissible pressure

- **expansion vessel**
 - allows the changes of fluid volume (due to thermal expansion) without extreme increase of pressure above non-permissible limit
 - **safety valve will not react during standard operation**
 - **even in case of stagnation**




Pressures in solar system






Safety (relief) valve

- **relief pressure**
 - respects pressure endurance of system components
 - influences size of expansion vessel






Safety (relief) valve





Location of safety valve


- between safety valve and collector must not be any valve
- pressure loss at vapour mass flowrate $< 3\%$ of relief pressure
- free outflow has to be assured from relief
- regular checks provided






Expansion vessel


- closed solar systems
 - pressure expansion vessel with a membrane



Delivery State



Solar System Filled,
Without Thermal Action



Maximum Pressure
at Highest Temperature
of Heat-Bearing Fluid



Size of expansion vessel

$$V_{\text{EN}} = (V_s + V \cdot \beta + V_k) \cdot \frac{p_e + p_o}{p_e - p_o}$$

V_s ... initial volume in exp.ves., $V_s = 1\text{-}10 \% V$, min 2 liters

V ... total fluid volume in collector loop [l]

β ... coefficient of thermal expansion for $\Delta t = t_{\text{max}} - t_0 = 120 \text{ K}$


V_k ... volume of solar collectors (evaporated in stagnation) [l]

p_e ... maximum operation pressure [kPa]

p_o ... minimum operation pressure (filling pressure) [kPa]



Coefficient of thermal expansion





Expansion vessel


- selection of expansion vessel from a manufacturer predefined sizes






Expansion vessel - location

right




wrong






Hydraulic stations – integration

- circulation pump
- closing valves
- check valve
- connection of expansion vessel
- safety valve
- thermometers







Hydraulic stations – integration







Air venting







Check valve

- eliminates spontaneous circulation in collector loop





Check valve





Controller

- **differential control** – temperature difference between collector and load (storage tank, swimming pool)

$\Delta T > \text{set „switch on“ value (8 K)}$ - circulation pump ON

$\Delta T < \text{set „switch off“ value (3 K)}$ – circulation pump OFF

- one-loop
- multi-loop

- **safety functions**

storage temperatures $> 85\text{ }^{\circ}\text{C}$ – circulation OFF

collector temperatures $> 130\text{ }^{\circ}\text{C}$ – circulation OFF






Controllers






Function





Control during a day





Evaluation of solar system – heat gains

$$Q = \dot{V} \rho c (t_2 - t_1) \cdot \Delta \tau$$

volume flowrate

thermophysical properties of fluid

input / output temperature

time period

